Basic Maintenance Checklist for Compressed Air Systems

- Check the air filter weekly
- ☐ Change the oil filter every 2,000 hours
- Keep your aftercooler/oil cooler clean
- Change your air/oil separator every 4,000 hours or annually
- Request an oil analysis every 2,000 hours



